


Corrigendum/Amendment:01

Title of Service: Supply, Installation, Testing And Commissioning Of Telecom Lithium-Ion Battery In Different Universities And PGCB Location.


Invitation Ref No: BdREN Trust/Procurement/2023/G7, dated: 10 February 2023

SL No.	Clause	Page No.	Section	Clause details	Corrigendum/Amendment
1	ITT 28.1(f)	29	Section: 2	Not Applicable	<i>Manufacturer Authorization is required: Manufacturer Authorization for Battery from Original Equipment Manufacturer (OEM), if the bidder is not manufacturer.</i>
2	3.1	77	Section:7	<ul style="list-style-type: none">● Weight: 58 Kg.● Higher Power: 442*410*221 (mm).	<ul style="list-style-type: none">● Weight: Maximum 58 Kg.● Dimension: 19" rack mountable



Pre-Bid Queries & Amendment Request of Bidder A
Title of Service: Supply, Installation, Testing And Commissioning Of Telecom Lithium-Ion Battery In Different Universities And PGCB Location.
Invitation Ref No: BdREN Trust/Procurement/2023/G7, dated: 10 February 2023

SL	Item/ Clause	Page #	Tender's Technical Specifications	Question/ Query/Recommendation	BdREN Response
1	ITT 36.1	30		In addition to the original of the Tender, 2 copy/copies shall be submitted.	Please follow the tender document
2	ITT 62.1	31		The amount of Performance Security shall be ten (10) percent of the Contract Price. Performance security will be released upon issuance of warranty completion certificate.	Please follow the tender document
3	ITT 62.3	31		The Security Deposit shall be deducted @Ten (10) percent from the successful Tenderer's payable invoices during Contract implementation, if awarded with the Contract.	Please follow the tender document
4	GCC 21.1	49		c)Manufacturer's/ Supplier's warranty certificate (if any);	Please follow the tender document. However, for ITT 28.1(f), please follow corrigendum/amendment-01.
5	Section 7 (Technical Specification) clause 7 (Implementation Period)	80		The supplier shall implement the project in 3 (Three) months.	Please follow the tender document
6	Extra Question	N/A		Will invoice VAT & TAX adjusted with import AIT, CD and VAT?	As per GCC clause 27.1, the Supplier shall be entirely responsible for all applicable taxes, custom duties, VAT and other levies imposed or incurred inside or outside Bangladesh.



Pre-Bid Queries & Amendment Request of bidder B
Title of Service: Supply, Installation, Testing And Commissioning Of Telecom Lithium-Ion Battery In Different Universities And PGCB Location.
Invitation Ref No: BdREN Trust/Procurement/2023/G7, dated: 10 February 2023

SL	Item/ Clause	Page #	Tender's Technical Specifications	Question/ Query/Recommendation	BdREN Response
1	Section 7. Technical Specifications,	80	3.4 Detail Specification of Telecom Lithium-ion Battery	So, Please Consider The Manufacture " Lighter Weight: Bidder should be mention" instead of "Lighter Weight: 58 Kg".	Weight (maximum): 58 kg. Please follow corrigendum/amendment-01.
2	Section 7. Technical Specifications,	80	3.4 Detail Specification of Telecom Lithium-ion Battery	So, Please Consider The Manufacture "Higher Power or dimension: Bidder should be mention" instead of "Higher Power: 442*410*221 (mm)".	Mountable in 19" rack. Please follow corrigendum/amendment-01

Pre-Bid Queries & Amendment RequestC
Title of Service: Supply, Installation, Testing And Commissioning Of Telecom Lithium-Ion Battery In Different Universities And PGCB Location.
Invitation Ref No: BdREN Trust/Procurement/2023/G7, dated: 10 February 2023

SL	Item/ Clause	Page #	Tender's Technical Specifications	Question/ Query/Recommendation	BdREN Response
1	ITT 62.1	31		The amount of performance security shall be Five (05) percent of the contract price	Please follow the tender document
2	ITT 62.3	31		The security Deposit shall be deducted five(05) percent from the successful tenderers' payable invoices during contract implementation if awarded the contract.	Please follow the tender document
3	Section 7. Technical Specifications,	80		Battery weight: Maximum 41-47.5 Kg	Weight (maximum): 58 kg, please follow corrigendum/amendment-01
4	GCC 21.1	49		c)Manufacturer's/ Supplier's warranty certificate (if any);	Please follow the tender document. However, for ITT 28.1(f), please follow corrigendum/amendment-01.

